

NWO- CFA Cell, 8th Floor, Corporate Office,
Bharat Sanchar Bhawan, H.C. Mathur Lane
Janpath, New Delhi-110001
Tel No 011-23716688, Fax No 23766033
Email: nwocfa@bsnl.co.in



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

No. 7-1 /2018/NWO-CFA/MSE/Fire

Dated: 03.04.2018

To

The CGMs
Telecom Circle/Telecom Districts/Mtce Regions.

Sub: Regarding safety from Fire incidents.

Recently, a fire incident had occurred at BTS site CICR Campus Khapri, Nagpur SSA, Maharashtra Telecom Circle. Investigation committee has suggested the following measures to be taken to avoid such fire incident in future.

1. It is suggested that electrical and RF cables should be provided with separate runway with separate entry holes.
2. Care should be taken to ensure that all cable leads are properly insulated.
3. Care should be taken to ensure that RF waveguides are not leaded at coupling or at any other point.
4. Cable entry holes remain closed to avoid entry of any rodent.

Apart from above, all existing guidelines & other instructions issued by this office time to time including engineering instructions on prevention of fire in telecommunication buildings & fire fighting should also be strictly followed.

This is issued with the approval of competent authority.

P.K.Sharma
09/04/18

(P.K.Sharma)
DGM (NWO-I-CFA)