

NWO- CFA Cell, 8th Floor, Corporate Office,
Bharat Sanchar Bhawan, H.C. Mathur Lane
Janpath, New Delhi-110001
Tel No 011-23716688, Fax No 23766033
Email: nwocfa@bsnl.co.in



भारत संचार निगम लिमिटेड
(भारत सरकार का उपक्रम)
BHARAT SANCHAR NIGAM LIMITED
(A Govt. of India Enterprise)

No. 7-1 /2018/NWO-CFA/MSE/Fire

Dated: 11.05.2018

To

The CGMs
Telecom Circle/Telecom Districts/Mtce Regions.

Sub: Regarding safety from Fire incidents.

Recently, a fire incident had occurred at OCB-283 Switch room located at 2nd floor, Telephone Exchange, Fafadih, Raipur Chhattisgarh Telecom Circle. Investigation committee has suggested the following measures to be taken to avoid such fire incident in future.

1. All electrical appliances and wiring may be checked periodically to avoid short circuiting in future.
2. Proper use of GD tubes/IPM in the MDF must be ensured.
3. Fire alarm control system to be checked regularly.
4. The proper working of A.C. units to be checked regularly.
5. OCB Rack external alarm wiring to be extended and it should be checked regularly.
6. The fire extinguishers, sand buckets may be regularly checked as per the standard schedule and day to day guidelines issued by BSNLCO.
7. Technical personnel may be on the duty in the OCB Switch Room round the clock.
8. Frequent inspection higher offices should be done and instruction should be issued for proper maintenance. Compliance of the instructions should be ensured.
9. Earth value to be checked as per the standard schedule and day to day guidelines issued by BSNL CO.
10. CCTV cameras may be installed at the suitable places for proper surveillance.
11. Pamphlets regarding instruction in case of fire to be available at the site.

Apart from above, all existing guidelines & other instructions issued by this office time to time including engineering instructions on prevention of fire in telecommunication buildings & fire fighting should also be strictly followed.

This is issued with the approval of competent authority.

P.K. Sharma
16/05/18

(P.K.Sharma)
DGM (NWO-I-CFA)